


SSTA

Heating & Ventilation in Schools



Heating (*Nothing new here*)

- Classrooms **17°C** (within 1 hour of school opening)
- Gymnasia **13°C**
- Games Hall **10°C**
- Assembly Hall / lecture hall **15.5°C**
- Cloakroom & corridors **13°C**

Ventilation

- Two changes of air per hour
- Calculation using volume and flow rate?
- Measure maximum CO2 concentration
- 1500 ppm is the recommended maximum



Action

- If these conditions are not met a new classroom that meets these conditions needs to be found.
- If it is not possible then the class should be sent home
- Please contact the SSTA Head Office for further advice

Legislation

- School Premises (General Requirements & Standards)(Scotland) Regulations 1967
- School Premises (General Requirements & Standards)(Scotland) Amendment Regulations 1973
- School Premises (General Requirements & Standards)(Scotland) Amendment Regulations 1979
- Workplace (Health, Safety and Welfare) Regulations 1992